

Certificate of Product Approval

Certificate Number: 1174e-(cl-1)

Issue: 02

V-GREAT GLOBAL CORPORATION

Second floor, Capital City,
Independence Avenue,
P.O. Box 1008,
Victoria,
Mahe,
Seychelles

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Control and Indicating equipment

VG-6831/16

VG-6831/8

VG-6831/4

VG-6831/2

(refer to Appendix for details)

Standards

EN 54-2:1997 + A1:2006

EN 54-4:1997 + A1:2002 + A2:2006

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

S. David

Verifier

15 April 2025

Date of Issue

12 May 2016

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1174e-(cl-1)

Issue: 02

V-GREAT GLOBAL CORPORATION

Certified Product	Description	LPCB Ref.No.
VG-6831/16	16 Zone Conventional Control and Indicating Equipment Incorporating the following units: VSL2.908.004 16 Zone Control Board VSL2.908.007 16 Zone Display Board PD-100-24 AC/DC Power Supply Module VSL2.908.005 16 Zone Signal Output Board Certified with the following Options with requirements from EN 54-2:1997: 7.8 Output to fire alarm device(s) 7.11 Delay to outputs 10 Test condition Note: 1. This product approval does not constitute compliance with the fire detection and fire alarm system requirements of EN 54-13 including fault monitoring and indication of degraded transmission paths.	1174e/01
VG-6831/8	8 Zone Conventional Control and Indicating Equipment Incorporating the following units: VSL2.908.042 8 Zone Control Board VSL2.908.043 8 Zone Display Board PD-100-24 AC/DC Power Supply Module VSL2.908.006 8 Zone Signal Output Board	1174e/02

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

S. David

Verifier

15 April 2025

Date of Issue

12 May 2016

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1174e-(cl-1)

Issue: 02

V-GREAT GLOBAL CORPORATION

Certified Product	Description	LPCB Ref.No.
	Certified with the following Options with requirements from EN 54-2:1997: 7.8 Output to fire alarm device(s) 7.11 Delay to outputs 10 Test condition Note: 1. This product approval does not constitute compliance with the fire detection and fire alarm system requirements of EN 54-13 including fault monitoring and indication of degraded transmission paths.	
VG-6831/4	4 Zone Conventional Control and Indicating Equipment Incorporating the following units: VSL2.908.044 4 Zone Control Board VSL2.908.045 4 Zone Display Board PD-100-24 AC/DC Power Supply Module VSL2.908.075 4 Zone Signal Output Board Certified with the following Options with requirements from EN 54-2:1997: 7.8 Output to fire alarm device(s) 7.11 Delay to outputs 10 Test condition Note:	1174e/03

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

S. David

Verifier

15 April 2025

Date of Issue

12 May 2016

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1174e-(cl-1)

Issue: 02

V-GREAT GLOBAL CORPORATION

Certified Product	Description	LPCB Ref.No.
	1. This product approval does not constitute compliance with the fire detection and fire alarm system requirements of EN 54-13 including fault monitoring and indication of degraded transmission paths.	
VG-6831/2	2 Zone Conventional Control and Indicating Equipment Incorporating the following units: VSL2.908.046 2 Zone Control Board VSL2.908.047 2 Zone Display Board PD-100-24 AC/DC Power Supply Module VSL2.908.074 2 Zone Signal Output Board Certified with the following Options with requirements from EN 54-2:1997: 7.8 Output to fire alarm device(s) 7.11 Delay to outputs 10 Test condition Note: 1. This product approval does not constitute compliance with the fire detection and fire alarm system requirements of EN 54-13 including fault monitoring and indication of degraded transmission paths.	1174e/04

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

S. David

Verifier

15 April 2025

Date of Issue

12 May 2016

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre